

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F1885

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

INTEGRA ASL Wall Mounting VACIE

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

Application Solutions (Safety and Security) Ltd
Unit 17 Cliffe Industrial Estate
Lewes
East Sussex
BN8 6JL
United Kingdom

Application Solutions (Safety and Security) Ltd
Unit 17 Cliffe Industrial Estate
Lewes
East Sussex
BN8 6JL
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-4:1997 + A1:2002 + A2:2006 - Power supply equipment
EN 54-16:2008 - Voice alarm control and indicating equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 16 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



E. Mattie-Suleiman, Certification Engineer

Date of First Issue: 16 October 2019

Date of Issue: 2 November 2020

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F1885**INTEGRA ASL Wall Mounting VACIE**

Incorporating the following:

INTEGRA All-in-one Wall Mount Voice Alarm System for D Series amplifiers and amplifier interfaces
OR

INTEGRA-PRO All-in-one Wall Mount Voice Alarm System for D Series amplifiers and amplifier interfaces
with Dante DSP Audio Processor (consists of INTEGRA and VIPEDIA-PRO)

D Series amplifiers:

D500 Amplifier Module 500W

D150 Amplifier Module 150W

Amplifier interfaces:

LSZDC Dual Line surveillance interface

V2000-STBY V2000 Standby Interface

Optional modules:

BMB01 RS485 Interfaced Analogue and Digital I/O Expansion Unit

BOA01 RJ45 DIN Terminal Breakout Adaptor – Single Port – With Terminations

BOA02 RJ45 DIN Terminal Breakout Adaptor – Four Port – Straight Through

VIPEDIA-NET Vipedia-12 Network Card

VIPEDIA-NET-4GB Vipedia-12 Network Card with 4GB Audio Storage Inc. VIPA-OS

VIPEDIA-PRO VIPEDIA-12 Network Card with Dante DSP Audio Processor

SFP Optional Modules:

SFP-CU1G SFP Module (Copper Ethernet)

SFP-MM1GL SFP Module (Multi-mode Fibre)

SFP-MM1GC SFP Module (Multi-mode Fibre)

SFP-SM1G SFP Module (Single-mode Fibre)



E. Mattie-Suleiman, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 16 October 2019

Date of issue: 2 November 2020

Issue number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie


APPENDIX to Certificate of constancy of performance: 2831-CPR-F1885

Optional Network Switches:

NETWORK-SWITCH-MM4	Multi-mode Secure Loop Switch (2*Fibre, 2*RJ45)
NETWORK-SWITCH-SM4	Single-mode Secure Loop Switch (2*Fibre, 2*RJ45)
NETWORK-SWITCH-MM8	Multi-mode Secure Loop Switch (2*Fibre, 6*RJ45)
NETWORK-SWITCH-SM8	Single-mode Secure Loop Switch (2*Fibre, 6*RJ45)
NETWORK-SWITCH-NF8	Secure Loop Switch (8*RJ45)
NETWORK-SWITCH-LP01	Network Loop Switch (2*SFP, 8*RJ45)

Optional Emergency Microphones:

EAP01	Emergency access point - All call emergency microphone
EMS01 (MK2)	Emergency microphone station - All call
EMS01-EC(MK2)	Emergency microphone station - All call with euro-cylinder lock
EMS10	Emergency microphone station - 10 Button
EMS10-EC	Emergency microphone station - 10 Button with euro-cylinder lock
EMS20	Emergency microphone station - 20 Button
EMS20-EC	Emergency microphone station - 20 Button with euro-cylinder lock
EMS30	Emergency microphone station - 30 Button
EMS40	Emergency microphone station - 40 Button
EMS50	Emergency microphone station - 50 Button
EMX30	Expansion module for EMS20 - 30 Button
MPS01-F	Desk paging and emergency microphone - 1 Button Fist mic
MPS01-G	Desk paging and emergency microphone - 1 Button Gooseneck mic
MPS10-F	Desk paging and emergency microphone - 10 Button Fist mic
MPS10-G	Desk paging and emergency microphone - 10 Button Gooseneck mic
MPS20-F	Desk paging and emergency microphone - 20 Button Fist mic
MPS20-G	Desk paging and emergency microphone - 20 Button Gooseneck mic
MPS30-F	Desk paging and emergency microphone - 30 Button Fist mic
MPS30-G	Desk paging and emergency microphone - 30 Button Gooseneck mic
MPS40-F	Desk paging and emergency microphone - 40 Button Fist mic
MPS40-G	Desk paging and emergency microphone - 40 Button Gooseneck mic
MPS50-F	Desk paging and emergency microphone - 50 Button Fist mic
MPS50-G	Desk paging and emergency microphone - 50 Button Gooseneck mic
MPX10	Microphone expansion module for MPS01 - 10 Button
MPS01-MB	Wall mount bracket kit for MPS01


E. Mattie-Suleiman, Certification Engineer,
On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 16 October 2019
Date of issue: 2 November 2020
Issue number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F1885

MPX10-MB Wall mount bracket kit for MPS10 - MPS20

Certified with the following options with requirements from EN 54 Part 16:

- 7.6.2 Manual silencing of voice alarm condition
- 7.7.2 Manual reset of the voice alarm condition
- 7.9 Voice alarm condition output
- 8.3 Indication of faults related to the transmission path to the CIE
- 8.4 Indication of faults related to voice alarm zones
- 10.0 Voice Alarm Manual control
- 12.0 Emergency microphone(s)
- 13.14 Redundant power amplifiers

Notes:

1. The certification is valid only when the installation and configuration of the VACIE meet the manufacture's system design guide and EN 54-16 functionality.
2. Refer to the ASL technical document reference number T-0667-0379 for further detail of ASL order numbers for product variants and third-party products tested and approved by BRE/LPCB to be used with or as part of ASL VACIE.



E. Mattie-Suleiman, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 16 October 2019

Date of issue: 2 November 2020

Issue number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.